

**Commonwealth of Massachusetts
Department of Telecommunications and Energy
Fitchburg Gas and Electric Light Company
Docket No. D.T.E. 02-24/25
Responses to the Attorney General's Sixth Set of Information Requests**

Request No. AG-6-17 (Gas)

If the Company's load forecast day ahead is not accurate, but has underprojected load, what do the Company's dispatchers do during the day to react to this underprojection.

Response:

The Company's dispatchers will complete intra day pipeline nominations to bring all available storage volumes to our city gate. Additionally, if the available pipeline volume is insufficient to meet the supply needs, the dispatcher would dispatch LNG or LPG supplies.

Person Responsible: Mark H. Collin